

CCMC

STANDARD COMPLIANCE
EVALUATION



CCMC 13447-L

CCMC Standard compliance evaluation

CCMC number:	13447-L
Status:	Active
Issue date:	2011-09-08
Modified date:	2022-11-17
Evaluation holder:	DDP Specialty Electronic Materials US, LLC (company of DuPont) 974 Centre Road, Building 730 Wilmington DE 19805 United States Website: www.dupont.com Telephone: 302-999-6387
Product name:	Froth-Pak™ Foam Sealant
Evaluation requirements:	<u>CAN/ULC-S711.1-11, Class 2</u>

In most jurisdictions this document is sufficient evidence for approval by Canadian authorities.

[Learn more about CCMC recognition](#) [Look for the trusted CCMC mark on products to verify compliance.](#)



National Research
Council Canada

Conseil national de
recherches Canada

Canada

Product information

Product name

Froth-Pak™ Foam Sealant

Product description

Froth-Pak™ Foam Sealant is a bead-applied two-component low-pressure, polyurethane foam used as an air sealant for building applications. The product is packaged in pressurized containers and is available in various sizes.

Manufacturing plant

This evaluation is valid only for products produced at the following plant:

Product name	Manufacturing plant
	Wilmington, IL, US
Froth-Pak™ Foam Sealant	Ⓢ

Ⓢ Indicates that the product from this manufacturing facility has been evaluated by the CCMC

Technical information

This evaluation is based on demonstrated conformance with the following criteria:

Criteria number	Criteria name
CAN/ULC-S711.1-11, Class 2	Standard for Thermal Insulation – Bead-Applied Two Component Polyurethane Air Sealant Foam, Part 1: Material Specification

Table 1. Air leakage rate after aging and time-to-occupancy specifications for the product

Product	Substrate qualification	Air leakage rate after aging ⁽¹⁾ (L/s·m)	Time-to-occupancy (h)
Froth-Pak™ Foam Sealant	Wood window to DuPont™ Tyvek® HomeWrap® at the sides and DuPont™ FlexWrap™ NF at the head and sill	0.01	25
	Vinyl window to DuPont™ Tyvek® HomeWrap® at the sides and DuPont™ FlexWrap™ NF at the head and sill	0.01	25

Notes:

¹ The criteria is 0.05 L/s at 75 Pa per metre joint length.

Administrative information

Disclaimer

This evaluation is issued by the Canadian Construction Materials Centre (CCMC), part of the Construction Research Centre at the National Research Council of Canada (NRC). The evaluation must be read in the context of the entire [CCMC Registry of Product Assessments](#) and the legislated applicable building code in effect.

The CCMC was established in 1988 on behalf of the applicable regulator (i.e., the provinces and territories) to ensure—through assessment—conformity of alternative and acceptable solutions to regional building codes as determined by the local authority having jurisdiction (AHJ) as part of the issuance of a building permit.

It is the responsibility of the local AHJs, design professionals, and specifiers to confirm that the evaluation is current and has not been withdrawn or superseded by a later issue. Please refer to [the website](#) or contact:

Canadian Construction Materials Centre

Construction Research Centre
National Research Council of Canada
1200 Montreal Road
Ottawa, Ontario, K1A 0R6
Telephone: 613-993-6189
Fax: 613-952-0268

The NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this evaluation are directed to those who have the appropriate degree of experience to use and apply its contents (i.e., AHJs, design professionals and specifiers). This evaluation is only valid when the product is installed in strict compliance with the stated conditions and limitations of evaluation and the applicable local building code. In circumstances where no applicable local building permit is issued and that no confirmation of compliance 'for use in the intended field application' is undertaken, this evaluation is null and void in all respects. This evaluation is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the NRC provides no endorsement for any evaluated material, product, system or service described herein. The NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this evaluation with respect to its compliance to the referenced code(s) and standard(s). The NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Language

Une version française de ce document est disponible.

In the case of any discrepancy between the English and French version of this document, the English version shall prevail.

Copyright

© His Majesty the King in Right of Canada, as represented by the National Research Council of Canada, 2022

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of the CCMC.

This PDF is an alternative version. This document was published on 2022-11-18 and may not be the latest version of this evaluation. Users should consult the latest [published assessment](#) on the [CCMC Registry of Product Assessments](#), which contains the most up to date information. This PDF is intended for use as a record, not the latest information available.

CCMC recognition

The Canadian Construction Materials Centre (CCMC) assesses compliance with Canadian building, energy and safety codes. We are the only construction code compliance service supported and operated by the Government of Canada. Trusted by over 6,000 regulators across Canada.

Most Canadian authorities having jurisdiction (AHJs) consider CCMC product assessments acceptable as evidence for product approval.

CCMC assessments are recognized by construction authorities across Canada:

Alliance of Canadian Building Official Associations (ACBOA)



(Alliance of Canadian Building Official Associations (ACBOA))

First Nations National Building Officers Association (FNNBOA)



(First Nations National Building Officers Association (FNNBOA))

Canadian Home Builders' Association (CHBA)



(Canadian Home Builders' Association (CHBA))

Alberta Building Officials Association (ABOA)



(Alberta Building Officials Associations (ABOA))

Saskatchewan Building Officials Association (SBOA)



(Saskatchewan Building Officials Association (SBOA))

Manitoba Building Officials Association (MBOA)



(Manitoba Building Officials Association (MBOA))

Ontario Building Officials Association (OBOA)



(Ontario Building Officials Association (OBOA))

New Brunswick Building Officials Association (NBBOA)



(New Brunswick Building Officials Association (NBBOA))

Nova Scotia Building Officials Association (NSBOA)



(Nova Scotia Building Officials Association (NSBOA))

The CCMC provides code compliance assessments to Canadian code requirements, consulting nationwide with construction regulators to elicit regional variations in code requirements as well as provincial and local interpretations. Users are advised to review the technical information presented in CCMC assessments when making approval decisions. [Learn more about how the CCMC provides a unique service for Canada.](#)

For more information, contact the CCMC by phone at (613) 993-6189 or by email at ccmc@nrc-cnrc.gc.ca