

## CCMC 13574-L

### CCMC Standard compliance evaluation

<b>CCMC number:</b>	13574-L
<b>Status:</b>	Active
<b>Issue date:</b>	2012-12-07
<b>Modified date:</b>	2021-11-17
<b>Evaluation holder:</b>	<p><b>Mule-Hide Products Co. Inc.</b>                      1195 Prince Hall Dr.                      Beloit WI 53511                      United States                      Website: <a href="http://www.mulehide.com">www.mulehide.com</a>                      Telephone: 608-365-3111, 800-786-1492                      Email: <a href="mailto:mulehide@mulehide.com">mulehide@mulehide.com</a></p>
<b>Product name:</b>	Mule-Hide PVC Membrane
<b>Evaluation requirements:</b>	<u>CAN/CGSB-37.54-95, Type: 4, Class: B</u>

In most jurisdictions this document is sufficient evidence for approval by Canadian authorities.

[Learn more about CCMC recognition](#)

## Product information

### Product name

Mule-Hide PVC Membrane

### Product description

Mule-Hide PVC Membrane is a flexible, polyvinyl chloride (PVC) membrane that is reinforced with an embedded fabric and used in roofing and waterproofing.

### Manufacturing plants

This evaluation is limited to products produced at the following plant(s):

- Greenville, Illinois, United States

### Technical information

This evaluation is based on demonstrated conformance with the following criteria:

Criteria number	Criteria name
<u>CAN/CGSB-37.54-95, Type: 4, Class: B</u>	Polyvinyl Chloride Roofing and Waterproofing Membrane

The roofing and waterproofing membranes are suitable for use in exposed and non-exposed applications. Only materials recommended by the manufacturer should be in contact with the membranes.

# Administrative information

## Disclaimer

This evaluation is issued by the Canadian Construction Materials Centre (CCMC), part of the Construction Research Centre at the National Research Council of Canada (NRC). The evaluation must be read in the context of the entire [CCMC Registry of Product Assessments](#) and the legislated applicable building code in effect.

The CCMC was established in 1988 on behalf of the applicable regulator (i.e., the provinces and territories) to ensure—through assessment—conformity of alternative and acceptable solutions to regional building codes as determined by the local authority having jurisdiction (AHJ) as part of the issuance of a building permit.

It is the responsibility of the local AHJs, design professionals, and specifiers to confirm that the evaluation is current and has not been withdrawn or superseded by a later issue. Please refer to [the website](#) or contact:

### Canadian Construction Materials Centre

Construction Research Centre  
National Research Council of Canada  
1200 Montreal Road  
Ottawa, Ontario, K1A 0R6  
Telephone: 613-993-6189  
Fax: 613-952-0268

The NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this evaluation are directed to those who have the appropriate degree of experience to use and apply its contents (i.e., AHJs, design professionals and specifiers). This evaluation is only valid when the product is installed in strict compliance with the stated conditions and limitations of evaluation and the applicable local building code. In circumstances where no applicable local building permit is issued and that no confirmation of compliance 'for use in the intended field application' is undertaken, this evaluation is null and void in all respects. This evaluation is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the NRC provides no endorsement for any evaluated material, product, system or service described herein. The NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this evaluation with respect to its compliance to the referenced code(s) and standard(s). The NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

## Language

Une version française de ce document est disponible.

In the case of any discrepancy between the English and French version of this document, the English version shall prevail.

## Copyright

© 2021 Her Majesty the Queen in Right of Canada, as represented by the National Research Council of Canada.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of the CCMC.

---

**This PDF is an alternative version.** This document was published on 2021-11-17 and may not be the latest version of this evaluation. Users should consult the latest [published assessment](#) on the [CCMC Registry of Product Assessments](#), which contains the most up to date information. This PDF is intended for use as a record, not the latest information available.

## CCMC recognition

The Canadian Construction Materials Centre (CCMC) assesses compliance with Canadian building, energy and safety codes. We are the only construction code compliance service supported and operated by the Government of Canada. Trusted by over 6,000 regulators across Canada.

Most Canadian authorities having jurisdiction (AHJs) consider CCMC product assessments acceptable as evidence for product approval.

### CCMC assessments are recognized by construction authorities across Canada:

Alliance of Canadian Building Official Associations (ACBOA)



[\(Alliance of Canadian Building Official Associations \(ACBOA\)\)](#)

First Nations National Building Officers Association (FNNBOA)



[\(First Nations National Building Officers Association \(FNNBOA\)\)](#)

Canadian Home Builders' Association (CHBA)



[\(Canadian Home Builders' Association \(CHBA\)\)](#)

Alberta Building Officials Association (ABOA)



[\(Alberta Building Officials Associations \(ABOA\)\)](#)

Saskatchewan Building Officials Association (SBOA)



[\(Saskatchewan Building Officials Association \(SBOA\)\)](#)

Manitoba Building Officials Association (MBOA)



[\(Manitoba Building Officials Association \(MBOA\)\)](#)

Ontario Building Officials Association (OBOA)



[\(Ontario Building Officials Association \(OBOA\)\)](#)

New Brunswick Building Officials Association (NBBOA)



[\(New Brunswick Building Officials Association \(NBBOA\)\)](#)

Nova Scotia Building Officials Association (NSBOA)



[\(Nova Scotia Building Officials Association \(NSBOA\)\)](#)

The CCMC provides code compliance assessments to Canadian code requirements, consulting nationwide with construction regulators to elicit regional variations in code requirements as well as provincial and local interpretations. Users are advised to review the technical information presented in CCMC assessments when making approval decisions. [Learn more about how the CCMC provides a unique service for Canada.](#)

For more information, contact the CCMC by phone at (613) 993-6189 or by email at [ccmc@nrc-cnrc.gc.ca](mailto:ccmc@nrc-cnrc.gc.ca)

For the latest version of this evaluation consult the [CCMC Registry of Product Assessments](#)