

CCMC 13673-R

CCMC Canadian code compliance evaluation

CCMC number:	13673-R
Status:	Active
Issue date:	2013-10-07
Modified date:	2023-11-08
Evaluation holder:	<p>Alexwill Distribution Inc. 237 Arvin ave. Stoney Greek ON L8E 5S6 Canada Website: www.hydrostarag.com Telephone: 905-547-9727 Email: support@hydrostarag.com</p>
Product name:	Hydrostar AG (Dampproofing)
Compliance:	NBC 2015, OBC
Criteria:	CCMC-TG-071119.01-15, "CCMC Technical Guide for Foundation Wall Dampproofing Systems – Dimpled Membranes"

In most jurisdictions this document is sufficient evidence for approval by Canadian authorities.

[Learn more about CCMC recognition](#) [Look for the trusted CCMC mark on products to verify compliance.](#)

Compliance opinion

It is the opinion of the Canadian Construction Materials Centre that the evaluated product, when used as a material for dampproofing in accordance with the conditions and limitations stated in this evaluation, complies with the following code:

National Building Code of Canada 2015

Code provision	Solution type
9.13.2. Dampproofing	<u>Alternative</u>

Ontario Building Code

Ruling No. 14-20-315 (13673-R) authorizing the use of this product in Ontario, subject to the terms and conditions contained in the Ruling, was made by the Minister of Municipal Affairs and Housing on 2014-10-27 (revised 2021-12-13) pursuant to s.29 of the Building Code Act, 1992 (see Ruling for terms and conditions). This Ruling is subject to periodic revisions and updates.

The above opinion(s) is/are based on the evaluation by the CCMC of technical evidence provided by the evaluation holder, and is bound by the stated conditions and limitations. For the benefit of the user, a summary of the technical information that forms the basis of this evaluation has been included.

Product information

Product name

Hydrostar AG (Dampproofing)

Product description

The product is a black, high-density, polyethylene, quasi-rigid plastic sheet membrane extruded in a manner that results in a dimpled surface on one side and a flat surface on the other. The dimpled surface is intended to provide an air gap between the wall and the adjacent soil. The product is produced from a mixture of virgin and recycled plastic materials. The product has dimples that are 7 mm high and is available in rolls that are 0.82 mm thick (the flat, i.e., non-dimpled area), 20 m long, and either 2.4 m, 2.1 m, 1.98 m, 1.8 m, 1.5 m or 1.2 m wide.

To ensure correct application, a range of accessories, such as fasteners, washers, plugs, and moulding strips, is included with the product.




Figure 1. Side facing soil




Figure 2. Side facing wall



Figure 3. Anchor with washer




Figure 4. Anchor with plug

Manufacturing plant

This evaluation is valid only for products produced at the following plant:

Product name	Manufacturing plant
	Filago BG, Italy
Hydrostar AG (Dampproofing)	☑

☑ Indicates that the product from this manufacturing facility has been evaluated by the CCMC

Conditions and limitations

The CCMC's compliance opinion is bound by this product being used in accordance with the conditions and limitations set out below.

- Based on the evidence provided, the products have been classified as "Type 2" for use in vertical applications in depths up to 3.7 m below grade. Application depths greater than 3.7 m are considered to be outside the scope of this evaluation.
- The products must be installed in accordance with the manufacturer's instructions. In the event of conflict between the manufacturer's instructions and this Report, this Report shall govern.
- The products were evaluated for use against cast-in-place and concrete block foundations only and must cover the foundation wall from the top of the footing to the final grade.
- The products must be used in locations where the foundation wall is well-drained in accordance with Subsection 9.14.2., Foundation Drainage, of Division B of the NBC 2015.
- The products are dimpled membrane drainage systems designed to act as a protective layer or a capillary breaking layer against the foundation wall to protect the wall against transient or intermittent water that may come in contact with the wall's surface.
- The products must be protected from exposure to ultraviolet (UV) light (sunlight) within a maximum of 30 days of installation.
- Long-term performance of the dampproofing system depends on local conditions such as the soil type, hydrogeology of the site, mineralogy and presence of microorganisms in the soil (i.e., iron ochre), as well as compatibility of the filter with the soil, among other considerations. Compliance with this Report does not exempt the project from requiring proper engineering design of the drainage system.
- The performance of fixtures used to anchor the products in the wall was evaluated for a single anchor. It is the responsibility of the manufacturer to define the pattern and spacing of anchors, considering the anchor strength as well as site-specific issues such as the type of soil, how it will interact with the products, as well as the backfilling method used.
- The top of the membrane and all vertical joints and terminations must be mechanically fastened and sealed to prevent soil particles from entering behind the membrane. Accessories used to anchor the product are part of the evaluation.
- The product's label and/or packaging must be clearly identified with the following:
 - manufacturer's name or logo; and
 - the phrase "CCMC 13673-R."

Technical information

This evaluation is based on demonstrated conformance with the following criteria:

Criteria number	Criteria name
CCMC-TG-071119.01-15	CCMC Technical Guide for Foundation Wall Dampproofing Systems – Dimpled Membranes

The Report Holder has submitted technical documentation for the CCMC's evaluation. Testing was conducted at laboratories recognized by the CCMC. The corresponding technical evidence for this product is summarized below.

Table 1. Test results for Hydrostar AG

Property		Unit	Requirement	Result
Compressive strength (initial)		kPa	≥ 150	357.7
Dynamic impact resistance (mean failure energy)		J	≥ 2.45	10.4
Creep resistance (residual thickness at 25 years/10°C)		%	≥ 40% at 25 years/ 10°C	86.2
Cold bending at -30°C		N/A	No visible crack	No visible crack
Tensile strength	at yield	kN/m	≥ 8	XD 9.5 (1)
	elongation at break	%	≥ 25	XD 27.5
	anisotropy ratio	N/A	≥ 0.5	0.99
	OIT after 2 weeks	minutes	5	14.2 (2)
	dimensional change	%	≤ 1	MD -0.6, XD -0.4
	weight change	%	≤ -0.1	-0.3
	residual compression strength	%	≥ 80 of initial	107
Heat aging (for 2 weeks)	OIT after 2 weeks	minutes	≥ 5	14.2 (2)
	dimensional change	%	≤ 1	MD -0.6, XD -0.4
	weight change	%	≤ -0.1	-0.3
	residual compression strength	%	≥ 80 of initial	107
	creep resistance after heat aging (residual thickness at 25 years/10°C)	%	Class B: ≥ 40% 25 years/10°C	88.4
Resistance to alkaline environment	appearance	N/A	No visible crack	No visible crack
	residual compression strength	%	≥ 80 of initial	98.7

This PDF is an alternative version. This document was published on 2024-02-29 and may not be the latest version of this evaluation. Users should consult the latest [published assessment](#) on the [CCMC Registry of Product Assessments](#), which contains the most up to date information. This PDF is intended for use as a record, not the latest information available.

Property	Unit	Requirement	Result
bending resistance	N/A	No visible crack	No visible crack
Geometrical properties			
Orientation of the dimples	–	Report value	Diagonal IMD/CD
Number of dimples per unit area	dimples/m ²	Report value	1 554
Overall thickness	mm	Report value	6.96
Sheet thickness	mm	Report value	0.82
Hollow core thickness	mm	Report value	6.14
Anchorage performance	kN/washer	Report value	0.29
Anchorage efficiency	kN/plug	Report value	0.31

Notes:

- 1 "MD" refers to the "machine direction" of the product. "XD" refers to the "cross direction" of the product.
- 2 For products exhibiting an oxidation induction time (OIT) greater than five minutes after exposure to heat for two weeks, the test duration is limited to two weeks in lieu of eight weeks.

Administrative information

Use of Canadian Construction Materials Centre (CCMC) assessments

This assessment must be read in the context of the entire [CCMC Registry of Product Assessments](#), any applicable building code or by-law requirements, and/or any other regulatory requirements (for example, the [Canada Consumer Product Safety Act](#), the [Canadian Environmental Protection Act](#), etc.).

It is the responsibility of the user to confirm that the assessment they are using is current and has not been withdrawn or superseded by a later version on the [CCMC Registry of Product Assessments](#).

Disclaimer

The National Research Council of Canada (NRC) has evaluated only the characteristics of the specific product described herein. The information and opinions in this evaluation are directed to those who have the appropriate degree of experience to use and apply its contents (such as authorities having jurisdiction, design professionals and specifiers). This evaluation is valid when the product is used as part of permitted construction, respecting all conditions and limitations stated in the evaluation, and in accordance with applicable building codes and by-laws.

This evaluation is provided without representation, warranty or guarantee of any kind, expressed or implied, and the NRC provides no endorsement for any evaluated product. The NRC accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained herein or the use of any evaluated product. The NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Language

Une version française de ce document est disponible.

In the case of any discrepancy between the English and French version of this document, the English version shall prevail.

Copyright

© His Majesty the King in Right of Canada, as represented by the National Research Council of Canada, 2024

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of the CCMC.

This PDF is an alternative version. This document was published on 2024-02-29 and may not be the latest version of this evaluation. Users should consult the latest [published assessment](#) on the [CCMC Registry of Product Assessments](#), which contains the most up to date information. This PDF is intended for use as a record, not the latest information available.

CCMC recognition

The Canadian Construction Materials Centre (CCMC) assesses compliance with Canadian building, energy and safety codes. We are the only construction code compliance service supported and operated by the Government of Canada. Trusted by over 6,000 regulators across Canada.

Most Canadian authorities having jurisdiction (AHJs) consider CCMC product assessments acceptable as evidence for product approval.

CCMC assessments are recognized by construction authorities across Canada:

Alliance of Canadian Building Official Associations (ACBOA)



(Alliance of Canadian Building Official Associations (ACBOA))

First Nations National Building Officers Association (FNNBOA)



(First Nations National Building Officers Association (FNNBOA))

Canadian Home Builders' Association (CHBA)



(Canadian Home Builders' Association (CHBA))

Alberta Building Officials Association (ABOA)



(Alberta Building Officials Associations (ABOA))

Saskatchewan Building Officials Association (SBOA)



(Saskatchewan Building Officials Association (SBOA))

Manitoba Building Officials Association (MBOA)



(Manitoba Building Officials Association (MBOA))

Ontario Building Officials Association (OBOA)



(Ontario Building Officials Association (OBOA))

New Brunswick Building Officials Association (NBBOA)



(New Brunswick Building Officials Association (NBBOA))

Nova Scotia Building Officials Association (NSBOA)



(Nova Scotia Building Officials Association (NSBOA))

The CCMC provides code compliance assessments to Canadian code requirements, consulting nationwide with construction regulators to elicit regional variations in code requirements as well as provincial and local interpretations. Users are advised to review the technical information presented in CCMC assessments when making approval decisions. [Learn more about how the CCMC provides a unique service for Canada.](#)

For more information, contact the CCMC by phone at (613) 993-6189 or by email at ccmc@nrc-cnrc.gc.ca

NOTICE

The information presented on this webpage (in HTML format) is the most up-to-date information available from the CCMC about this assessment.

By downloading this PDF you acknowledge that:

- this PDF is intended for record-keeping purposes only,
- it represents the information as it was available at the time of downloading, and
- it may not reflect the latest available information at some future date.

References to this CCMC assessment (in product literature, on websites, etc.) must be made by linking to the evaluation webpage. **This PDF must not be used as a means of distributing this assessment to an audience.**

[View PDF \(Portable document format\)](#)

Code compliance as an acceptable solution

Code Compliance via Acceptable Solutions

If a building design (e.g. material, component, assembly or system) can be shown to meet all provisions of the applicable **acceptable solutions** in Division B (e.g. it complies with the applicable provisions of a referenced standard), it is deemed to have satisfied the objectives and functional statements linked to those provisions and thus to have complied with that part of the Code.

— National Building Code of Canada, Sentence A-1.2.1.1.(1)(a)

The CCMC has determined that compliance with this provision of the Code has been demonstrated as an **Acceptable Solution**. The evaluation report provides a summary of the basis of CCMC's compliance opinion.

CCMC's code compliance opinions

All CCMC evaluation reports are opinions of code compliance established in accordance with the National Building Code of Canada, Subsection 1.2.1. "Compliance with this Code," which requires compliance to be achieved by:

- complying with the applicable acceptable solutions in Division B, or
- using an alternative solution that will achieve at least the minimum level of performance required by Division B in the areas defined by the objective and functional statements attributed to the applicable acceptable solutions.

The CCMC assesses compliance with Canadian building, energy and safety codes, and is trusted by over 6,000 regulators across Canada.

Code compliance as an alternative solution

Code Compliance via Alternative Solutions

Where a design differs from the acceptable solutions in Division B, then it should be treated as an **"alternative solution."** A proponent of an alternative solution must demonstrate that the alternative solution addresses the same issues as the applicable acceptable solutions in Division B and their attributed objectives and functional statements. However, because the objectives and functional statements are entirely qualitative, demonstrating compliance with them in isolation is not possible. Therefore, Clause 1.2.1.1.(1)(b) identifies the principle that Division B establishes the quantitative performance targets that alternative solutions must meet. In many cases, these targets are not defined very precisely by the acceptable solutions [...] Nevertheless, Clause 1.2.1.1.(1)(b) makes it clear that an effort must be made to demonstrate that an alternative solution will perform as well as a design that would satisfy the applicable acceptable solutions in Division B—not “well enough” but “as well as.”

— National Building Code of Canada, Sentence A-1.2.1.1.(1)(b)

The CCMC has determined that compliance with this provision of the Code has been demonstrated as an **Alternative Solution**. The evaluation report provides a summary of the basis of CCMC's compliance opinion.

CCMC's code compliance opinions

All CCMC evaluation reports are opinions of code compliance established in accordance with the National Building Code of Canada, Subsection 1.2.1. "Compliance with this Code," which requires compliance to be achieved by:

- complying with the applicable acceptable solutions in Division B, or
- using an alternative solution that will achieve at least the minimum level of performance required by Division B in the areas defined by the objective and functional statements attributed to the applicable acceptable solutions.

The CCMC assesses compliance with Canadian building, energy and safety codes, and is trusted by over 6,000 regulators across Canada.